



Technical requirements:

1. The cabinet surface shall be sprayed with grayish white or light gray, and the coating shall meet the requirements of GB/ t381-1995
2. Outdoor cabinet materials shall be made of adiabatic flame retardant plate materials with a thickness of not less than 45mm, and color steel plates with a thickness of not less than 0.5mm shall be used inside and outside the adiabatic flame retardant plate plates.
3. The temperature, relative humidity, operating temperature range:
 - 40 °C ~ + 50 °C storage temperature range: 25 °C ~ + 55 °C
 Transportation temperature range: - 45 °C ~ + 70 °C relative humidity:5% ~ 100%.
4. The net size of the internal space is 800 (length) *350 (depth) *1800 (height);
5. The cabinet adopts natural ventilation, and the door louver is used for air inlet.

NLC12-50

Battery cabinet (16pcs)